



P.C.C. (CLASS B) THRUST
 BLOCK MIN. 1.5 SQ. FT.
 SOLID EARTH BEARING

1. EXPOSED THREADS ON STEEL PIPE SHALL BE SCOTCH WRAPPED FOR CORROSION PROTECTION.
2. WELD OR FORM CAULKING BEAD ON STEEL PIPE.

CITY OF PASADENA ENGINEERING-STREET DEPARTMENT

STANDARD F. H. LATERAL DETAIL

STANDARD PLAN

APPROVED

[Signature]
 CITY ENGINEER & SUPT. OF STREETS

3-9-66
 DATE

S - 208